

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0900:129 Page 1 of 1

CATEGORY: Control Unit (Non High-Rise)

LISTEE: Fike Protection Systems, 704 S. 10th St., Blue Springs MO 64015
Contact: Sean Titus (816) 229-3405

DESIGN: Model SHARK (p/n 10-056 fire alarm control unit. Power limited, local, noncoded, manual and automatic, waterflow, and sprinkler supervisory service. Refer to listee's data sheets for additional detailed product description and operational considerations. Basic components:

70-1767-R, 70-1771		Enclosure
10-2323	DB	Mainboard
02-4812	PS	Power Supply
10-2326	SLM	Loop Module
10-2254	CPPM	Reverse Polarity Module
10-2256	DACT	Digital Alarm Communicator Transmitter
10-2321		Remote Display
*10-2325		Keypad

RATING: 120/240 VAC Input; 24 VDC Standby

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed compatible initiating and indicating devices. The control unit can generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal as required (for total evacuation) per NFPA 72, 1999 Edition. Refer to manufacturer's Installation Manual for details.

NOTE: For Fire Alarm Verification Feature (delay of fire alarm signal), the maximum Retard/Reset/Restart period shall not exceed 30 seconds.

*Corrected 01-10-2003 BH



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JANUARY 10, 2003**

*Listing Expires **June 30, 2003***

Authorized By: **DIANE K. AREND, Senior Deputy**
Program Manager